

Manufacturing Plant : Clow Canada, Saint John, New Brunswick

Catalogue Number 300-360-390

Production Description : Restrainers for PVC Pipe

Size : 4" - 24"

Material : Cast Ductile Iron
A-536 Gr 65-45-12

Material Specifications and Test Details :

All sizes meet or exceed the requirements of UNI-Bell specifications UNI-B-13-92 and ASTM F1674

All sizes are made of high strength grade 65-45-12 ductile iron with the requirements and specifications of ASTM A536

The 300C restrainer in Sizes 4" to 12" are FM (Factory Mutual) approved as meeting their recognized standard class number 1620


We hereby certify that the above products were inspected and tested in accordance with relevant specifications and found acceptable.



Quality Assurance



Date



Engineering and Operations Manager



Date