CLOW
Canada

CERTIFICATE OF COMPLIANCE

Manufacturing Plant : Clow Canada, Saint John, New Brunswick

Production Description : D67M - Premier Fire Hydrant

Product Design / Testing : AWWA C502, Dry-Barrel Fire Hydrants (250psi rating)
AWWA C550, Protective Interior Coatings for Valves and Hydrants
(ULC) Underwriters Laberatories of Canada
(FM) Factory Mutual
UL (Underwriters Laberatories) in accordance with **ANSI/NSF 61 and ANSI/NSF 372**
(LEAD CONTENT VERIFICATION OF PRODUCTS INCONTACT WITH POTABLE WATER)

Size : 5" **Type :** Dry Barrel

Quantity : **Cat. No. :** D67M

Material Specifications and Test Details :

Clow Canada models are manufactured to the following material specifications

Materials	ASTM Standard	
Cast Iron	A-126-B	
Ductile Iron	A-536 65-45-12	
Bronze	B-584 867 Alloy	(Tripod)
Bronze	B-584 836 Alloy	(Remainder of Castings)
Steel Bar Stock (Stem)	A-576	
Stainless Steel (Upper Stem)	416 MX	

Hydrostatic Test: **Shell: 500 p.s.i.** **SEAT: 500 p.s.i.**

We hereby certify that the above products were inspected and tested in accordance with relevant specifications and found acceptable.

Quality Assurance — Date: 11-20-13

Plant Manager — Date: 11-20-13

Effective 2013 (November)