



Clow Valve Co.

902 South 2nd Street
Oskaloosa, IA 52577

Telephone: 641 673-8611
Fax: 641 673-8269

CERTIFICATE OF COMPLIANCE & TESTING

INDICATOR POST

The Clow Model 2945 Indicator Post is approved by Underwriters Laboratories and Factory Mutual Research. The Indicator Post fully complies with UL Standards 789 and the FM Standard Class #1110. The Indicator Post is designed for the operation of 4"-16" Resilient Seated Gated Valves. The indicator post also meets NFPA24 standards. All Model 2945 Indicator Posts are manufactured in Elmira, New York.