

Manufacturing Plant : Clow Canada, Saint John, New Brunswick

Production Description : M67B Brigadier Fire Hydrant
M93B Brigadier Fire Hydrant
M67B Brigadier Fire Hydrant with 3" Monitor Outlet
M67B Brigadier Fire Hydrant (Heritage Style - Octagonal Boby)

Product Design / Testing: AWWA C502, Dry-Barrel Fire Hydrants (250psi rating)
AWWA C550, Protective Interior Coatings for Valves and Hydrants
(ULC) Underwriters Laboratories of Canada
(FM) Factory Mutual
(UL) Underwriters Laboratories in accordance with ANSI/NSF 61 and NSF/ANSI 372
(LEAD CONTENT VERIFICATION OF PRODUCTS IN CONTACT WITH POTABLE WATER)

Size : 5 1/4"

Type : Dry Barrel

Quantity :


Cat. No. : M67B

Material Specifications and Test Details :


This document certifies that this product is manufactured and tested in accordance with AWWA C502 and that the materials used shall meet or exceed the requirements of the related ASTM standards.

<u>Materials</u>	<u>ASTM Standard</u>
Cast Iron	A-126-B
Ductile Iron	A-536 65-45-12
Bronze	B-584 87850 Alloy
Bronze	B-584 867 Alloy (Drip Valve)
Steel Bar Stock (Stem)	A-576
Stainless Steel (Upper Stem)	416 MX

We hereby certify that the above products were inspected and tested in accordance with relevant specifications and found acceptable.




Quality Assurance



Date



Plant Manager



Date