

An industry leader in underground and in-plant applications.

BUTTERFLY VALVES

STYLE 4500 3" – 24"
STYLE 1450 30" – 54"

Consult factory for
sizes 60" – 120"



C504 • Class 150B & 250B



M&H VALVE COMPANY

CLOW
CLOW CANADA

www.clowcanada.com



For Generations

BUTTERFLY VALVES



AWWA Class 150B Butterfly Valves

M&H Style 4500: 3" – 24"

1450: 30" – 54" (Consult Factory for valves 60" – 120")

RECOMMENDED SPECIFICATIONS

1. All butterfly valves shall be of the rubber-seated, tight-closing type. They shall meet or exceed AWWA standard C504, latest edition, Class 150. All valves shall be M&H 4500/1450 butterfly valves, or approved equal.
2. Both ends shall be ANSI A21.11 mechanical joint or per flanged ANSI B16.1 (or as otherwise noted on plans and specs).
3. Valve shafts shall be ASTM A276 Type 304 stainless steel. Each valve shaft shall be of a one-piece design for valves 12" and smaller and a two-piece design for valves 14" and larger. Valve shafts shall have a minimum diameter extending through the valve bearings and into the valve disc as specified in AWWA C504. All valve shafts must meet or exceed the minimum connection torque requirement set forth in AWWA C504.
4. For valve sizes 3" – 16", valve body and vane shall be high-strength cast iron to ASTM A126, Class B or high-strength ductile iron to ASTM A536 with ASTM A276 Type 304 stainless steel body seats.
5. For valves 18" and larger, valve body and vane shall be of high-strength ductile iron to ASTM A536, Grade 70-50-05 with ASTM A276 Type 304 stainless steel body seat.
6. Rubber valve seats shall be a full-circle 360 degree, seat not penetrated by the valve shaft. Valve seat shall be EPDM for cold or high water temperature applications.
7. The valve seat will be attached to the valve vane by 18-8 Type 304 stainless steel self-locking fasteners. The valve seat must be easily field adjustable and replaceable without any special tools or lengthy curing time.
8. Valve shaft seals shall be of the O-ring type and utilize the same elastomer as specified for the valve seats and for the intended service. Valves using self-compensating split V-type packing will not be accepted. All valve shaft seals must be easily field replaceable.
9. Valve actuator shall be of the traveling nut type, sealed and lubricated for underground or in-plant service. Operator shall be capable of withstanding an overload input torque of 450 ft-lbs. at full-open or full-closed position without damage to the valve operator. Operators for valves 14" and larger must have a 304 stainless steel external stop limiting device and travel adjustment. The travel adjustments must be able to be operated without removing the valve from the line or removing the actuator cover. No internal travel adjustment devices will be acceptable. All valve actuators must be sized per AWWA C504. Certification of proof of design and torque requirements shall be submitted to the owner upon request.
10. Handcrank, Handwheel or Chainwheel – All manual operators for service other than underground shall have a position indicator and shall be totally enclosed and permanently lubricated. Actuators shall be designed to produce the required operating torque with a maximum rim pull of 80 lb. on handwheel or chainwheel and a maximum input of 150 ft. lb. on operating nuts.
11. Cylinder – Cylinder operator shall be of the base mounted configuration. Cylinder barrel shall be of molybdenum-disulfide lined glass fiber reinforced epoxy tubing, to provide a corrosion-free, self-lubricated high-strength barrel. Rod seal shall be of urethane, molybdenum-disulfide filled, to provide a self-lubricated, long life seal.
12. The valve interior and exterior surfaces shall be coated in accordance with the latest revisions of AWWA C504 and must be NSF 61 Certified.



M&H VALVE COMPANY



AWWA Class 250B Butterfly Valves

M&H Style 4500: 4" – 24"

1450: 30" – 48"

RECOMMENDED SPECIFICATIONS


1. All butterfly valves shall be of the rubber-seated, tight-closing type. They shall meet or exceed AWWA standard C504, latest edition, Class 250. All valves shall be M&H 4500/1450 butterfly valves, or approved equal.
2. Both ends shall be ANSI A21.11 mechanical joint or per flanged ANSI B16.1 (or as otherwise noted on plans and specs).
3. Valve shafts shall be ASTM A564 Type 630 stainless steel. Each valve shaft shall be of a one-piece design for valves 12" and smaller and a two-piece design for valves 14" and larger. Valve shafts shall have a minimum diameter extending through the valve bearings and into the valve disc as specified in AWWA C504. All valve shafts must meet or exceed the minimum connection torque requirement set forth in AWWA C504.
4. All valve bodies and vanes 4" – 48" shall be of high-strength ductile iron to ASTM A536, Grade 70-50-05 with ASTM A276 Type 304 stainless steel body seat.
5. Rubber valve seats shall be a full-circle 360 degree, seat not penetrated by the valve shaft. Valve seat shall be EPDM for cold or high water temperature applications.
6. The valve seat will be attached to the valve vane by 18-8 Type 304 stainless steel self-locking fasteners. The valve seat must be easily field adjustable and replaceable without any special tools or lengthy curing time.
7. Valve shaft seals shall be of the O-ring type and utilize the same elastomer as specified for the valve seats and for the intended service. Valves using self-compensating split V-type packing will not be accepted. All valve shaft seals must be easily field replaceable.
8. Valve actuator shall be of the traveling nut type, sealed and lubricated for underground or in-plant service. Operator shall be capable of withstanding an overload input torque of 450 ft.-lbs. at full-open or full-closed position without damage to the valve operator. Operators for valves 14" and larger must have a 304 stainless steel external stop limiting device and travel adjustment. The travel adjustments must be able to be operated without removing the valve from the line or removing the actuator cover. No internal travel adjustment devices will be acceptable. All valve actuators must be sized per AWWA C504. Certification of proof of design and torque requirements shall be submitted to the owner upon request.
9. Handcrank, Handwheel or Chainwheel – All manual operators for service other than underground shall have a position indicator and shall be totally enclosed and permanently lubricated. Actuators shall be designed to produce the required operating torque with a maximum rim pull of 80 lb. on handwheel or chainwheel and a maximum input of 150 ft. lb. on operating nuts.
10. Cylinder – Cylinder operator shall be of the base mounted configuration. Cylinder barrel shall be of molybdenum-disulfide lined glass fiber reinforced epoxy tubing, to provide a corrosion-free, self-lubricated high-strength barrel. Rod seal shall be of urethane, molybdenum-disulfide filled, to provide a self-lubricated, long life seal.
11. The valve interior and exterior surfaces shall be coated in accordance with the latest revisions of AWWA C504 and must be NSF 61 Certified.

AWWA C504 BUTTERFLY VALVES



M&H VALVE COMPANY

Traveling Nut Operator 3" – 42" Butterfly Valves




450 FT-LBS. OVERLOAD PROTECTION. Overloads developed by excessive input torque are absorbed instead of being transmitted to mechanism and valve. Lets you apply up to 450 ft-lbs. input torque at open and closed positions without damage to valve or operator.

PERMANENTLY SEALED. Underground operator is permanently lubricated and sealed from ground water.

REDUCES WATER HAMMER. Operator design is such that constant input speed results in variable output speed with slowing down of valve closure at ends of travel. This effect reduces water hammer, while maintaining rated output torque throughout entire travel.

AWWA OPERATING NUT. The two-inch square operating nut on the underground operator is clearly marked with "open" and direction arrow. All other operators have position indicators, which clearly show "open-shut" positions.

Rubber to Stainless Seating Style 4500 3" – 24" Butterfly Valves



RUBBER TO STAINLESS SEATING provides bubble-tight, permanent closure.

The unique vane-seat and body-seat construction of the M&H butterfly valve assures you of 100% bubble-tight sealing for the life of the valve.

The 304 **STAINLESS STEEL SEAT (1)** is made integral with the valve body for a permanent, corrosion-resistant seating area.

The **RUBBER SEAT (2)** is vulcanized to the stainless steel **SEAT-RETAINING RING (3)**, which is firmly clamped to the vane by stainless steel **SELF-LOCKING SCREW FASTENERS (4)**. This construction forms a positive lock between vane and rubber seat, which assures 360 degree leak-free seating.

ENGINEERING FEATURES

STYLE 1450 BUTTERFLY VALVE

30" – 54"

The Class 150B 36" valve is featured in this cutaway. Check out mh-valve.com for additional materials, end configurations by size and pressure class options.

BEARINGS
Generously sized, stainless steel backed, Teflon bearings provided on operator and thrust ends are self-lubricated, providing low friction support for the life of the valve. No maintenance is required.

OFFSET VANE DESIGN
Newly engineered vane provides large free flow area without sacrificing vane strength. Vane construction is of A536 ductile iron to meet or exceed AWWA standard C504.

VALVE BODY
Heavy duty ASTM A536 ductile iron body designed and manufactured to meet or exceed AWWA standard C504.

SEALING SYSTEM
Sealing system in which the seal is locked into a vane recess and is further restrained by a segmented clamp ring. Seal relaxation when the valve is in the open position is eliminated.


You are assured of uninterrupted 360 degree reliable and mechanically adjusted sealing as well as reduced wear and lower seating torque. Should field adjustment be required, one person with a torque wrench does the job without valve disassembly.

STAINLESS STEEL SHAFT
Ruggedly constructed valve shafts of 304 stainless steel meet or exceed AWWA standard C504.

O-RING CARTRIDGE
Maximum shaft sealing efficiency with a non-adjustable bronze O-ring cartridge

TAPER PINS
Full metal-to-metal contact, vane to shaft connection is accomplished by stainless steel taper pins secured with stainless steel lock nuts.

ADJUSTABLE THRUST BEARING
Bronze thrust bearing accurately centers vane in valve body. Accurate alignment is held in installation position. Factory adjusted for life of the valve.



- 1 VANE
- 2 360 DEGREE RUBBER SEAT
- 3 STAINLESS STEEL SELF-LOCKING SCREW FASTENER; WITH NYLON SLEEVE
- 4 STAINLESS STEEL BODY SEAT RING
- 5 STAINLESS STEEL SEAT RETAINING RING
- 6 VALVE BODY

ACCESSORIES / OPTIONS



FLOOR STANDS
F5500 N.R.S.
F5505 N.R.S. INDICATING



FLOOR BOX
F5695 BUSHED TO MEET STEM
 DIAMETER SPEC
 MAX. LENGTH 12"
 MAX. STEM DIAMETER 2 1/4"




MOTOR OPERATOR



CYLINDER OPERATOR



STEM GUIDES
F5660



T-HANDLE VALVE WRENCHES
F2520 RIGID WRENCH



EXTENSION STEMS
 UP TO 2 1/4" DIAMETERS
 ANY LENGTH

SIZE	MIN. LENGTH*	MAX. LENGTH*
#1	2 1/2"	17"
#2	15"	24"
#3	24"	35"

* Distance from wall



COMMITTED TO ENVIRONMENTAL RESPONSIBILITY

CLOW CANADA IS COMMITTED TO PROTECTING OUR NATURAL RESOURCES THROUGH ENVIRONMENTALLY RESPONSIBLE MANUFACTURING PRACTICES, INCLUDING THE USE OF 80+% RECYCLED CONTENT IN OUR HYDRANTS AND VALVES.



www.clowcanada.com



M&H VALVE COMPANY



1757 Burlington Str. East, P.O. Box 2849, Hamilton, Ontario. L8N 3R5
 PHONE 905-548-9604 FAX 905-548-6885



For Generations